



Wastewater Service Line Inspection Form

Tapping into the mainline is *NOT* permitted between October 15 and April 15

Call 970-349-7575 x104 to schedule an inspection at least 48 hours in advance. Inspections occur Mon-Thur only

Address:

Contractor/Contact:

Service Line Size:

Pipe Material:

Trench Depth:
*Minimum 7' deep

Type of Bedding:

Required Tracer Wire: Yes
Required Green Utility Marking Tape: Yes
Insulation: Yes/No

Gradient (2%-30% limits):

Number of Clean-outs: _____ Distance Between Clean-outs: _____
*First clean-out must be no more than 100 feet from building and no more than 100 feet apart

Saddle-Tap Connection: Connections must be at least ten feet from a manhole and must tap into the main with a saddle tap horizontally to the main (3 or 9 o'clock). Wye tap connections can be at 22° or 45° angles.

Saddle-Tap Horizontal to Main **Wye-Tap 22° or 45°**

To be completed by MCBWSD Inspector.

MCBWSD Inspector:

Date of Inspection:

Comments: