

Wastewater Service Line Inspection Form

Tapping into the mainline is *NOT* permitted between October 15 and April 15

Call 970-349-7575 x104 to schedule an inspection at least 48 hours in advance. Inspections occur Mon-Thur only

Address:

Contractor/Contact:

Service Line Size:

Pipe Material:

Trench Depth:
*Minimum 7' deep

Type of Bedding:


Tracer Wire: Yes/No
Insulation: Yes/No

Gradient (2%-30% limits):

Number of Clean-outs: <input style="width: 90%;" type="text"/>	Distance Between Clean-outs: <input style="width: 90%;" type="text"/>
*First clean-out must be no more than 100 feet from building and no more than 100 feet apart	

Saddle-Tap Connection: Connections must be at least ten feet from a manhole and must tap into the main with a saddle tap horizontally to the main (3 or 9 o'clock).


Wye tap connections can be at 22° or 45° angles.



Main Line Cross Section

Service Line 6 Service Line

Saddle-Tap Horizontal to Main



Wye-Tap 22° or 45°

To be completed by MCBWSD Inspector

MCBWSD Inspector:

Date of Inspection:

Comments: