



Water Service Line Inspection Form

Tapping into the mainline is *NOT* permitted between October 15 and April 15

Call 970-349-7575 x112 to schedule an inspection at least 48 hours in advance. Inspections occur Mon-Thur only

Address:

Contractor/Contact:

Service Line Size:

Pipe Material:

Trench Depth:
*Minimum 7' deep

Type of Bedding:

Required Tracer Wire: Yes
Required Blue Utility Marking Tape: Yes

Insulation: Yes/No

Saddle-Tap Connection: Place saddle at 45° angle from the top of pipe. Lay the new service perpendicular to the water main. Service line must have a corporation and a curb stop. Service line must be pressurized for inspection.

To be completed by MCBWSD Inspector.

MCBWSD Inspector:

Date of Inspection:

Diagram for location of curb stop: Triangulate off two corners of the foundation or known points.

Comments: